

November 4, 2008

INVACARE CORP.
RON TUCKER
1200 TAYLOR ST
ELYRIA OH 44036

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: INVACARE CORP.
Product Name: RECESSED ACCESS BATH TUB
Model Number(s): RECESSED SIDE ACCESS TUB 3600, 3600XL, 3650, 3750 AND 3800
Product File No: 20080505

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This product must discharge its waste to an acceptable receptor in accordance with s. Comm 82.33 (8) of the Wis. Adm. Code.
- This product shall be supplied from the manufacture with vacuum breakers that conform to ASSE 1011 or 1014 installed in the products water piping. One of them located between the mixing valve and the hand held shower and the other located between the mixing valve and the disinfectant injector (vacuum venturi).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov